

TREATMENT TECHNIQUE VIOLATION

The Texas Commission on Environmental Quality ("TCEQ") sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites, which can cause symptoms such as nausea, diarrhea, and associated headaches.

The City of Mart Public Water System failed to meet the minimum treatment techniques on December 30, 2008

Specifically our water system: allowed the turbidity of the filtered water to exceed 1.0 Nephelometric Turbidity Units.

Our water system had one 4-hour period with combined filter effluent turbidity reading above 1.0 NTU

If you want more information about the nature and significance, of this violation you may contact Daniel Ives at 254-876-2462.

Please share this information with all other people you think drink this water, especially those who may not have received this notice directly (for example people in nursing homes, apartments, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Rhonda -

Please post
to website
for 30 days

begin date : Jan 29, 09
end date Feb. 28, 09