

CERTIFICATION OF DELIVERY FOR PUBLIC NOTICE

The Texas Commission on Environmental Quality (“TCEQ”) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites, which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

The City of Mart Water System failed to meet the minimum treatment technique requirements on July 2007. Specifically, our water system, on July 20th through July 30th had 12 days with combined filter effluent turbidity above 1.0 NTU.

The City Of Mart Water System has taken the following corrective actions to prevent reoccurrences of the violations: Raised the Raw Water Intakes to change quality of raw water entering the plant.

If you want more information about the nature and significance of this violation, contact Ray Teakell at 254-876-2462

Please share this information with all other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

The Texas Commission on Environmental Quality (“TCEQ”) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites, which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

The City of Mart Water System failed to meet the minimum treatment technique requirements for the month of July 2007. Specifically, our water system reported 9.5% combined filter effluent turbidity readings exceeded 0.3 NTU. This exceeds the 5.0% limit for the month.

The City Of Mart Water System has taken the following corrective actions to prevent reoccurrences of the violations: Raised the Raw Water Intakes to change quality of raw water entering the plant.

If you want more information about the nature and significance of this violation, contact Ray Teakell at 254-876-2462

Please share this information with all other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

The Texas Commission on Environmental Quality (“TCEQ”) requires public water systems to monitor drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During July 2007, the City of Mart Water System did not conduct the proper testing for: 60-4-hour periods when the plant was on-line but combined filter effluent turbidity data were not collected.

We cannot be sure of the quality of your drinking water during that time.

The City Of Mart Water System has taken the following corrective actions to prevent reoccurrences of the violations: A new continuous Chlorine and Turbidity Analyzer was purchased and installed to record turbidity and Chlorine readings.

If you want more information about the nature and significance of this violation, contact Ray Teakell at 254-876-2462

Please share this information with all other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.